



efectis
nederland

Declaration of test results

2014-Efectis-R0236a-D

Efectis Nederland BV hereby declares that

a steel double leaf door- / frame construction, type AL-D/D50, built in a standard low density rigid supporting construction, was subjected to a fire test. Each door leaf had a dimension of 1120 x 2640 mm (w x h).

The test was performed by Efectis Nederland BV on the 25th of April 2014 according to EN 1634-1:2014, the European test standard for doors.

The investigated door construction fulfilled the criteria required for an EI₁₆₀, EI₂₆₀ and EW60 classification.

For EI₂₆₀ and EW60 the maximum allowable dimension of the door leaf is 1288 x 3036 mm (w x h). For EI₁₆₀, 1120 x 2640 mm (w x h).

These results are also valid for door types AL-D/D45, 52, 54 and 56 as assessed by Efectis described in report 2014-Efectis-R0236c dated October 2014.

The complete details of the test performed are recorded in Efectis test report 2014-Efectis-R0236a.

This declaration is valid until:
October 2019

Place and date:
Bleiswijk, October 6, 2014

This declaration is issued to:

On behalf of Efectis Nederland BV:

Alara Lukagro BV
P.O. Box 15
2964 ZG GROOT-AMMERS
The Netherlands


W. Scheffer BBE
Project leader fire resistance