



**efectis**  
nederland

---

## Declaration of test results

2015-Efectis-R000679-D

Efectis Nederland BV hereby declares that

a steel double leaf door- / frame construction, type **AL-D 50 S**, built in a standard low density rigid supporting construction, was subjected to a fire test. The doors opening away from the furnace. The double doorset had overall dimensions of 2362 x 3185 mm (w x h), each door leaf a width of 1150 mm.

The test was performed by Efectis Nederland BV on the 24<sup>th</sup> of April 2015 according to **EN 1634-1:2014**, the European test standard for doors.

The investigated door constructions fulfilled the criteria required for an **EI<sub>190</sub>** and **EI<sub>290</sub>** classification.

Extended application standard **EN 15269-2:2012**:  
For EI<sub>290</sub> and EW90 the dimensions of the door leaf may be increase by 25 % in width/height, maximum 30 % in area.

The complete details of the test performed are recorded in Efectis test report 2015-Efectis-R000679.

*This declaration is not a substitute for the above mentioned test report.*

*Place and date:*  
Bleiswijk, October 29, 2015

---

*This declaration is issued to:*

---

*On behalf of Efectis Nederland BV:*

---

Alara Lukagro BV  
P.O. Box 15  
2964 ZG GROOT-AMMERS  
The Netherlands

  
W. Scheffer BBE  
Project leader fire resistance

---